University of Georgia : General Lab Safety Assessment Rev. 1 Rev. 1 Required corrective actions to safety deficiencies are due two weeks after receipt of this report. Questions or assistance contact -			
		Department: Building: / Laboratory: / Inspection Date: 2021-08-23	Principal Investigator: Lab Contact: Lab Contact Phone: Lab Contact Email:
		A. IMMEDIATELY DANGEROUS CONDITIONS	
A.1 A.01 The primary means of egress out of the lab is at least 36 inches wide. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:	A.2 A.02 Gas cylinders (including lecture cylinders) are upright and secured with a chain, strap, or some other device specifically designed for securing cylinders. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:		
A.3 A.03 Pyrophoric gases and toxic gases (including carbon monoxide) present in the lab are kept in an NFPA compliant gas room, approved gas cabinet or exhausted enclosure. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Cylinders of pyrophoric gases that are greater than lecture bottle size that are located in laboratories shall be kept in approved fire suppression system gas cabinets. Comment:	A.4 A.04 No untended or unidentified spills on lab benches, floors, storage cabinets, or within fume hoods. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:		
B. CRITICAL DEFICIENCIES			
B.1 B.01 Appropriate personal protective equipment is available and utilized when necessary. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Flame resistant lab coats should be worn when working with pyrophoric materials outside of an inert atmosphere (e.g., glovebox). [] Since respirators are present in this space, users must be enrolled under the Respiratory Protection Program in most cases. Please contact occhealth@uga.edu to determine the need for enrollment. Comment:	B.2 B.02 No evidence of sink disposal of chemicals, unless the lab has written permission from the Environmental Safety Division. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Please refer to the Drain Disposal Guidelines found on the UGA Environmental Safety Division website. Comment:		
B.3 B.03 Liquid corrosives are stored in appropriate secondary containment. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Please place liquid corrosives into an appropriate secondary containment segregated by hazard class (inorganic acids, organic acids, oxidizing acids, bases). Comment:	B.4 B.04 Chemicals are segregated and stored according to hazard class. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Chemicals should be stored in accordance with the Guidelines for Chemical Storage and Management found in the Lab Safety Manual on UGA s Office of Research Safety website. Comment:		
B.5 B.05 Peroxide forming chemicals are found with proper	B.6 B.06 Fire extinguishers, eyewashes and safety showers		

labels indicating a receipt date, opening date, and testing information if applicable. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Please refer to the Peroxide Forming Chemicals section of the Lab Safety Manual available on the UGA Office of Research Safety website. Comment:	are unobstructed. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Eyewashes must be flushed at least once per week and this flushing should be documented in accordance with Eyewashes and Safety Shower guidelines found in the Lab Safety Manual on the UGA Office of Research Safety website. [] One or more of these units was found to not have been inspected within the last 12 months. Your inspector will contact the appropriate office to have this corrected. No further corrective action is required on the part of the lab. [] One or more of these units was obstructed. Please keep areas around these units unobstructed at all times. [] Safety plumbing was inspected with the primary lab space. Comment:
B.7 B.07 Electrical panels and gas shutoff valves in the lab are unobstructed. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:	
O LADODATORY CONDITIONS	
C. LABORATORY CONDITIONS C.1 C.01 Door windows to exterior corridors are uncovered.	C.2 C.02 Unless stored along walls, items are not stored
[] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Door windows should remain uncovered unless the lab is using exposed lasers or conducting light-sensitive research. [] Please remove or relocate any items that impede emergency evacuation from the lab. Comment:	within 18 inches of the ceiling in sprinklered rooms or within two feet of the ceiling in non-sprinklered rooms. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] In sprinklered labs, do not store any items within 18 of the ceiling so spray is not impeded in the event of a fire. [] The minimum ceiling clearance is not required for storage along walls. Comment:
C.3 C.03 The lab is free of slip, trip, and fall hazards in main areas of egress/ingress. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:	C.4 C.04 The laboratory caution sign is present on all main entrances into the lab or lab suite and accurately reflects the current emergency contact information. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:
C.5 C.05 All Research Safety provided laboratory postings and labels are visible and legible (emergency phone numbers, refrigerator stickers, eyewash/safety shower, spill kit, first aid kit, safety information sign). [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:	C.6 C.06 No evidence of food and/or beverage preparation or consumption. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Preparation and consumption of food and drink are not allowed in the laboratory. Storage is allowed only if all other options external to the lab have been ruled not viable.

	Comment:
C.7 C.07 Laboratory personnel are wearing appropriate laboratory attire. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Natural fiber clothing must be worn under flameresistant lab coats and on the legs and feet of personnel when working with pyrophoric materials outside of a glovebox. [] Shorts and open-toed shoes are not allowed to be worn inside of wet-bench laboratories. Comment:	C.8 C.08 Hand washing facilities have a sufficient supply of paper towels and soap present in the lab or lab suite. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Soap and paper towels are required for use in all wet-bench laboratories. If custodial personnel are not allowed in the lab, then it is the lab s responsibility to ensure that soap and paper towels are present. Comment:
C.9 C.09 Furniture at the lab benches is made of or covered with non-porous materials. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Furniture made of porous materials are only permitted at computer desks within a lab. Furniture either made of or covered with non-porous materials may be in areas where chemicals and biohazards are used. Comment:	<pre>C.10 C.10 Sharps, pointed plastics, and glass are being disposed of in appropriate containers. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] All glass disposal boxes must be lined with a sturdy bag. [] Any container going into the glass disposal box should be free of standing liquid. [] Any glass disposal box that has been compromised by liquid should be immediately removed from the laboratory and disposed of by lab staff. [] It is the responsibility of laboratory personnel to close, seal, and transport glass disposal boxes to the dumpster themselves. Comment:</pre>
D. CHEMICAL STORAGE	
D.1 D.01 All chemical containers within the lab are clearly labeled with either the full chemical name or an acceptable abbreviation. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Labels are fading and becoming illegible. Please replace these labels as soon as possible. [] Please label all in use containers with contents, even those containing water. Comment:	D.2 D.02 No hazardous liquids are stored above shoulder height. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:
D.3 D.03 The lab s chemical inventory accurately reflects the hazards present in the lab. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Hazardous chemicals are listed in an undefined storage location within your Chematix inventory. If these chemicals are present in the lab, update Chematix with their proper storage location. If they have been used, remove them from Chematix. [] Original containers of hazardous chemicals were found to not be barcoded. If you need additional barcodes please use the chat function within Chematix to request them. Comment:	D.4 D.04 Unused cylinders have safety caps in place. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:

D.5 D.05 All cylinders are tagged as Full, In Use, or Empty. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:	D.6 D.06 Cylinders in storage containing incompatible gases are separated by the required distance. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:
D.7 D.07 There is no evidence of stockpiling gas cylinders within the lab. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Labs are allowed to have a cylinder actively delivering gas to a process and a spare cylinder for that process in the lab at any time. Additional cylinders are considered stockpiling. Comment:	D.8 D.08 The volume and density of flammable liquids being stored and used in the laboratory does not exceed the limits established by the National Fire Protection Agency. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:
D.9 D.09 Flammable liquids requiring refrigeration are being stored in an intrinsically safe or explosion proof unit. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:	D.10 D.10 Hazardous waste containers are labeled with the words Hazardous Waste, the associated hazard class or other indication of hazard (e.g., original container label), and a sufficient description of contents. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:
D.11 D.11 Hazardous waste containers are kept tightly closed unless adding waste. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:	D.12 D.12 Liquid hazardous waste is being stored either in secondary containment or in a container rated for transport on public roads. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:
D.13 D.13 Incompatible waste is separated by a physical barrier. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:	D.14 D.14 No inherently waste-like containers are being stored. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:
E. SAFETY EQUIPMENT AND DOCUMENTATION	
E.1 E.01 Fire extinguishers, eyewashes, and safety showers are available and have been certified within the last 12 months. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Inspected with primary lab space. [] Your inspector will contact the appropriate office to have this corrected. No further corrective action is required on the part of the lab. Comment:	E.2 E.02 A first aid kit and spill kit are present and appropriately stocked in the lab or lab suite. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] If the lab utilizes mercury thermometers, a mercury spill kit should be available in the lab. [] Kits are located in the primary lab space. Comment:

] Not Inspected] Satisfactory] N/A] Unsatisfactory] Hazardous waste training is required to be pleted annually by all laboratory personnel luding faculty members. Training is available via Professional Education Portal (pep.uga.edu)] Inspected with primary lab space.] Lab Safety Basics is a one-time course required all lab users at UGA and is available via the fessional Education Portal (pep.uga.edu)] One or more lab users has yet to review the labific Chemical Safety Plan for this lab. These ald be available via the Professional Education tal (pep.uga.edu).] Right-to-Know training is required to be pleted annually by all laboratory personnel luding faculty members. Training is available via Professional Education Portal (pep.uga.edu) comment:
E.06 Fume hoods have been certified within the last 12 on the and appear to be operating within the parameters wired for maximum protection. Not Inspected Satisfactory N/A Unsatisfactory Hood air flow appears to be compromised and not widing adequate protection due to clutter and use of the fume hood area. One or more fume hoods has not been certified min the last 12 months. Your inspector will contact appropriate office to have this corrected. No other corrective action is required on the part of lab.
F.02 Electrical cords are not frayed or damaged.] Not Inspected] Satisfactory] N/A] Unsatisfactory comment:

Comment:	
F.3 F.03 Electrical equipment is properly grounded. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:	F.4 F.04 Outlets within six feet of a water source are equipped with GFCI protection. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:
F.5 F.05 Only UL rated power strips are used to power electronic equipment. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Some power strips in the lab are UL rated but not surge protected. It is recommended that all power strips used with computerized equipment be surge protected. Comment:	F.6 F.06 Power strips and extension cords are plugged directly into a permanent wall receptacle and not plugged into one another. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:
F.7 F.07 Power strips and extension cords being used in the lab are not being overloaded. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory [] Power strips are not intended for high load equipment, such as refrigerators, microwave ovens, space heaters, etc. Please contact Research Safety to discuss alternatives for powering high load equipment or have FMD install a wall outlet. Comment:	F.8 F.08 Any motors and pumps with moving belts are equipped with belt guards. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:
F.9 F.09 All equipment containing oil is being stored within secondary containment or on a spill pad if near a floor drain or sink. [] Not Inspected [] Satisfactory [] N/A [] Unsatisfactory Comment:	
Additional Comments	
Remedy Date:	
Suggested Actions	